



MET Laboratories, Inc.

Baltimore, MD Union City, CA Santa Clara, CA
410-354-3300 510-489-6300 408-748-3585

www.metlabs.com

December 7, 2011

Tigo Energy, Inc.
420 Blossom Hill Road # 100
Los Gatos, CA 95032

Congratulations! It is our pleasure to inform Tigo Energy, Inc. that the MM-JES, as will be defined in the MET Laboratories' Test Report 33442, has successfully completed and is compliant with the following tests performed at MET Laboratories, Inc.

- **IEC 60529:**
 - **Table 1: First Characteristic Numeral**
 - IP6X – 12.2 Protected against access to hazardous parts with a wire (1.0 mm probe)
 - **Table 2: First Characteristic Numeral**
 - IP6X – 13.4/13.6 Dust-Tight - Category 1, with under pressure
 - **Table 3: Second Characteristic Numeral**
 - IPX5 – 14.2.5 Protected against water jets
 - IPX7 – 14.2.7 Protected against the effects of temporary immersion in water

Please contact me with any questions or comments.

Sincerely,

Edmund Aryee
Manager, ESL Laboratory
earyee@metlabs.com

Created with

nitro PDF professional

The Nation's First Nationally Recognized Testing Laboratory Licensed by OSHA View this document online at nitropdf.com/professional